EPA Official Record

Mail ID: OFED1E7C93.AC079AEC-ON86257B2C.006F8EFB-85257B2C.006F9085

From: John Lovell

To: Jlovell

Delivered Date: 03/12/2013 04:19 PM EDT

Subject: Fw: Perfluoractanoic Acid (PFOA)

John Lovell
Pretreatment Coordinator
EPA Region 3
1650 Arch Street
Philadelphia, PA 19103-2029
215-814-5790
215-814-2318 (fax)

----- Forwarded by John Lovell/R3/USEPA/US on 03/12/2013 04:18 PM -----

From: John Lovell/R3/USEPA/US

To: "Davis, Richard" <richardda@state.pa.us>

Cc: Evelyn MacKnight/R3/USEPA/US@EPA, Elizabeth Ottinger/R3/USEPA/US@EPA

Date: 01/13/2009 11:10 AM

Subject: RE: Perfluoractanoic Acid (PFOA)

I talked to the person in charge of our drinking water enforcement branch and she talked about detection levels of 0.001 ppb. There apparently is an approved drinking water method, but my impression is that there are not a lot of labs that do the analysis. She mentioned MPI Research in State College, Severn Trent (she wasn't sure where that one was located but she thought out west), and Test America in Denver.

John Lovell Pretreatment Coordinator EPA Region 3 1650 Arch Street Philadelphia, PA 19103-2029 215-814-5790 215-814-2302 (fax)

"Davis, Richard" <richardda@state.pa.us>

John

Do you have anybody done there who might be able to answer the question how low a concentration of PFOA can be measured? I tried two commercial laboratories that I am

familiar with and because they have never run it, they can't answer the question. I am concerned because if we are asked for a direct discharge limit and that limit is so low it can't be measured, I think I would like to know that from the git-go.

Thanks, Byron

----Original Message----

From: Lovell.John@epamail.epa.gov [mailto:Lovell.John@epamail.epa.gov]

Sent: Friday, January 09, 2009 2:26 PM

To: Davis, Richard

Subject: Re: Perfluoractanoic Acid (PFOA)

To be honest, I don't know that much about it either, although I can forward a couple of e-mails that I sent to Deb Hoag at Reading. I'm still looking into it a bit as well.

John Lovell Pretreatment Coordinator EPA Region 3 1650 Arch Street Philadelphia, PA 19103-2029 215-814-5790 215-814-2302 (fax)

> "Davis, Richard" <richardda@state .pa.us>

> 01/09/2009 01:54

PM

John Lovell/R3/USEPA/US@EPA

CC

To

Subject

Perfluoractanoic Acid (PFOA)

Hi John

I have been asked to attend a meeting next Thursday with a manufacturer and representatives of a POTW that has an industrial waste pretreatment program. The manufacturer wants to discuss "any possible issues" concerning their discharge that would contain PFOA. Quite frankly, I had never heard of PFOA before this request. The only information I have was taken from a email from the manufacturer's consultant to someone in our community relations department and is as follows: Perfluoroactanoic (PFOA) is a fluorosurfactant used in an etching process. PFOA is a precursor of FSO-100 and has been subject of numerous studies linking low level exposure to PFOA and increased risk of cancer to animals. In 2006, DuPont and EPA entered into a voluntary Stewardship Program to significantly reduce emissions of PFOA by 2010 and completely eliminate the manufacture and purchase or use by 2015. Apparently (per the email) PFOA and its derivatives and precursors are not specifically regulated by the EPA; however, some state and local regulatory jurisdictions have PFOA on their radar (that's cryptic). Regulations may follow or already exist (again per the email). Have you ever heard of PFOA? How would the introduction of this chemical affect a IWPP? Are you aware of any limits for either direct discharge or pretreatment limits? Anything would help John.

Thanks again, Byron

R Byron Davis | Permit Engineer Department of Environmental Protection Southcentral Region 909 Elmerton Avenue | Harrisburg, PA 17110 Phone: 717.705.4824 | Fax: 717.705.4760 www.depweb.state.pa.us